



**Business Services
Contracts Office**

5735 47th Avenue • Sacramento, CA 95824
(916) 643-2464

*Janea Marking, Chief Business Officer
Robert Aldama, Purchasing Manager II*

ADDENDUM NO. 1

Date: May 9, 2024

Issued by: Sacramento City Unified School District

**Project: Project #: 0825-465
Serna Center Complex Security Upgrades**

This addenda shall supersede the original Information, attachments, and specifications regarding Project No. 0825-465 where it adds to, deletes from, clarifies or otherwise modifies them. All other conditions and any previous addenda shall remain unchanged.

Part A – Bidding and Contract Requirements

AD1.01 QUESTIONS

None

AD1.02 DRAWINGS

Addendum Item No. AD1.01- Serna Center - A111 Enlarged Floor Plan Lobby

- New Work Keynote No. 6, revise to read as follows: "At top of partial height wall, install cantilevered partition system by 3Form. System shall be the Iltuo Cantilever with Varia panels or approved equal. Provide all necessary trim, rails, base plates, 3/8 inch thick Varia panels, etc. for a complete system. System shall be anchored to top of existing partial height wall and shall extend vertically to close gap from stair intermediate landing to lower ground lever. Provide quantity and size as shown."

Addendum Item No. AD1.02- Central Enrollment - A112 Enlarged Floor Plan Central Enrollment Lobby

- New Work Keynote No. 8, revise referenced sheet from 10/A552 to 10/A551.
- New Work Keynote No. 9, revise referenced sheet from A552 to A551.
- Add General Sheet Note No. 3 to read as follows, "Contractor shall remove existing carpet as required to install steel posts/footings along with new walls. Provide new carpet to match existing. Provide Tandus Aftermath II roll as basis of bid."

END OF ADDENDUM NO. 1

Acknowledgement of this Addendum will be required at time of bid